

REQUEST FOR INFORMATION/CLARIFICATION



7010 E Acorn Drive, Ste 104
Scottsdale, Az 85254
480.481.9699
fax 480.425.8624

RFI. # 004

TO: Proteus Group
223 West Erie - Suite 6W
Chicago, Il 60610

DATE: March 10, 2008

PHONE: 312-337-7800
FAX: 312-337-7805

REQUESTED BY: DELMASTRO + EELLS

PROJECT: Fortis College
PROJ #: 10078

ATTN: Barry Koncel

SPEC REFERENCE : _____

REF: Addendum 2

DRAWING REFERENCE: _____

VERIFICATION

DISCREPANCY

OTHER

REQUEST : Potential cost or schedule impact

→Please provide dimensions & specific locations for both shafts. The west shaft obviously is determined by the location of the exhaust hood assembly along with the Fisher Hamilton Fume Hood. The east shaft appears to be located at compressor room #2109C, and is intended for the 2" lines for the air compressor & vacuum pump. Please clarify.

→

→

BY: J.Cotton

SIGNED: J Cotton

DATE: 10-Mar-08

ARCHITECT'S/ENGINEER'S RESPONSE :

(This information is provided as an interpretation of the Contract Documents for implementation)

See response to RFI #2 for location of the west (fume hood) shaft. The east shaft above the Compressor room #2109C has been eliminated. (2) 2" pipes for the air compressor and vacuum pump will run in the 3rd floor G3 column enclosure.

BY: Iwona Swift

SIGNED: _____

DATE: 3/17/2008

(RESPONSE DISTRIBUTION VIA) FAX: _____ MAIL: _____ DATE: _____

cc: Delmastro Eells: _____

Architect: _____

SUBS: _____