

REQUEST FOR INFORMATION/CLARIFICATION



7010 E Acorn Drive, Ste 104
Scottsdale, Az 85254
480.481.9699
fax 480.425.8624

RFI. # 005

TO: Proteus Group
223 West Erie - Suite 6W
Chicago, Il 60610

DATE: March 10, 2008

PHONE: 312-337-7800
FAX: 312-337-7805

REQUESTED BY: DELMASTRO + EELLS

PROJECT: Fortis College
PROJ #: 10078

ATTN: Barry Koncel

SPEC REFERENCE : _____

REF: Addendum 2

DRAWING REFERENCE: SPE.2

VERIFICATION

DISCREPANCY

OTHER

REQUEST : Potential cost or schedule impact

→ Please clarify if the Delta 2 specifications on sheet SPE.2, of the Henry Schein Dental Plans, are deleting all of the specifications including the exhaust fans (23, 23A) & the floor receptacles at the dental chairs (4A, 5, 6B).

→

→

BY: J.Cotton

SIGNED: J Cotton

DATE: 10-Mar-08

ARCHITECT'S/ENGINEER'S RESPONSE :

(This information is provided as an interpretation of the Contract Documents for implementation)

Refer to attached email response from C. Boston/CAI dated 03/20/08 @ 2:34 PM.

BY: Barry Koncel

SIGNED: _____

DATE: 3/20/2008

(RESPONSE DISTRIBUTION VIA) FAX: _____ E-MAIL: X

DATE: 3/21/2008

cc: Delmastro Eells: X

Architect: X

SUBS: _____

Barry J. Koncel

From: Chrissy Boston [ChrissyB@creativeaccess.net]
Sent: Thursday, March 20, 2008 2:34 PM
To: Iwona Swift
Cc: Barry J. Koncel; Susan Barfield; Andrea Davies; Will Green
Subject: Phoenix-RFI #5

Iwona-
I finally got a response regarding RFI #5 from the dental vendor...

No deletions are made. Plan shows exhaust fans, floor receptacles, & conduit.

You may also want to remind them that they are to be building off of the Architectural/Mechanical/electrical/Plumbing drawings and that the dental drawings are for reference purposes.

Thanks!

Chrissy Boston, IIDA | Sr. Project Manager

Creative Access, Inc.

8137 Main Street
Ellicott City, MD 21043
410-750-3490 | 410-299-8649 cell
410-750-3496 fax
chrissyb@creativeaccess.net
www.creativeaccess.net