

**REQUEST FOR INFORMATION/CLARIFICATION**



7010 E Acorn Drive, Ste 104  
Scottsdale, Az 85254  
480.481.9699  
fax 480.425.8624

**RFI. # 008**

TO: Proteus Group  
223 West Erie - Suite 6W  
Chicago, Il 60610

DATE: March 10, 2008

PHONE: 312-337-7800  
FAX: 312-337-7805

REQUESTED BY: DELMASTRO + EELLS

PROJECT: Fortis College  
PROJ #: 10078

ATTN: Barry Koncel

SPEC REFERENCE : \_\_\_\_\_

REF: \_\_\_\_\_

DRAWING REFERENCE: \_\_\_\_\_

VERIFICATION

DISCREPANCY

OTHER

REQUEST :  Potential cost or schedule impact

→ Does the Fisher Hamilton exhaust hood require a separate fire suppression system, such as the Ansul pull station?

→

→

BY: J.Cotton

SIGNED: J Cotton

DATE: 10-Mar-08

**ARCHITECT'S/ENGINEER'S RESPONSE :**

(This information is provided as an interpretation of the Contract Documents for implementation)

**Per directions from Creative Access, Inc. and Kraemer Engineering a separate suppression system for the fume hood is not required.**

BY: Iwona Swift

SIGNED: \_\_\_\_\_

DATE: 3/20/2008

(RESPONSE DISTRIBUTION VIA ) FAX: \_\_\_\_\_ MAIL: \_\_\_\_\_ DATE: \_\_\_\_\_

cc: Delmastro Eells: \_\_\_\_\_

Architect: \_\_\_\_\_

SUBS: \_\_\_\_\_