

REQUEST FOR INFORMATION/CLARIFICATION



7010 E Acorn Drive, Ste 104
Scottsdale, Az 85254
480.481.9699
fax 480.425.8624

RFI. # 010

TO: Proteus Group
223 West Erie - Suite 6W
Chicago, Il 60610

DATE: March 12, 2008

PHONE: 312-337-7800
FAX: 312-337-7805

REQUESTED BY: DELMASTRO + EELLS

PROJECT: Fortis College
PROJ #: 10078

ATTN: Barry Koncel

SPEC REFERENCE : _____

REF: Openings 2101, 2102, 2106, 2130A

DRAWING REFERENCE: _____

VERIFICATION

DISCREPANCY

OTHER

REQUEST : Potential cost or schedule impact

→Please clarify if door openings 2101, 2102, 2106 and 2130A are type "A" frames with a type "C" window frame, or are they a type "E" side light frame.

→

→

BY: J.Cotton

SIGNED: J Cotton

DATE: 12-Mar-08

ARCHITECT'S/ENGINEER'S RESPONSE :

(This information is provided as an interpretation of the Contract Documents for implementation)

Listed doors are frame type A per Opening Schedule. Borrowed lights have separate opening numbers (ex. 2101A, 2102A..) and are frame type C as shown in the Opening Schedule. Please note that frame type E is for Alternate #1 only which, if approved, would replace all doors type B and borrowed lights type C with solid doors type A with a side light. Frame type E is not in the base bid.

BY: _____

SIGNED: _____

DATE: _____

(RESPONSE DISTRIBUTION VIA)

FAX: _____ MAIL: _____

DATE: _____

cc: Delmastro Eells: _____

Architect: _____

SUBS: _____