

**REQUEST FOR INFORMATION/CLARIFICATION**



7010 E Acorn Drive, Ste 104  
Scottsdale, Az 85254  
480.481.9699  
fax 480.425.8624

**RFI. # 021**

TO: Proteus Group  
223 West Erie - Suite 6W  
Chicago, Il 60610

DATE: March 19, 2008

PHONE: 312-337-7800  
FAX: 312-337-7805

REQUESTED BY: MKB

PROJECT: Fortis College  
PROJ #: 10078

ATTN: Iwona Swift

SPEC REFERENCE : \_\_\_\_\_

REF: \_\_\_\_\_

DRAWING REFERENCE: \_\_\_\_\_

VERIFICATION

DISCREPANCY

OTHER

REQUEST :  Potential cost or schedule impact

→The overall drawing dimension of rooms #2127 & #2128. Drawings show an overall dimension of 56'-11", per detail 4/A500. Actual dimension is 56'-9 1/4". Please verify that the 1 3/4" difference is to be made up in room #2128, reducing the overall width of this room by 1 3/4".

→

→

BY: J.Cotton

SIGNED: J Cotton

DATE: 19-Mar-08

**ARCHITECT'S/ENGINEER'S RESPONSE :**

(This information is provided as an interpretation of the Contract Documents for implementation)

**Yes, the 1 3/4" dimension can be made up in Room 2128. South edge of N/S wall between Rooms 2127 and 2128 can be incorporated into build-out around Column E-5.**

BY: Barry Koncel

SIGNED: \_\_\_\_\_

DATE: 3/21/2008

(RESPONSE DISTRIBUTION VIA ) FAX: \_\_\_\_\_ E-MAIL: x

DATE: 3/21/2008

cc: Delmastro Eells: x

Architect: x

SUBS: \_\_\_\_\_