

**REQUEST FOR INFORMATION/CLARIFICATION**



7010 E Acorn Drive, Ste 104  
Scottsdale, Az 85254  
480.481.9699  
fax 480.425.8624

**RFI. # 024**

TO: Proteus Group  
223 West Erie - Suite 6W  
Chicago, Il 60610

DATE: March 21, 2008

PHONE: 312-337-7800  
FAX: 312-337-7805

REQUESTED BY: DELMASTRO + EELLS

PROJECT: Fortis College  
PROJ #: 10078

ATTN: Barry Koncel

SPEC REFERENCE : \_\_\_\_\_

REF: \_\_\_\_\_

DRAWING REFERENCE: \_\_\_\_\_

VERIFICATION

DISCREPANCY

OTHER

REQUEST :  Potential cost or schedule impact

→Please confirm that level 4 texture is acceptable.
→
→

BY: J.Cotton

SIGNED: J Cotton

DATE: 21-Mar-08

**ARCHITECT'S/ENGINEER'S RESPONSE :**

(This information is provided as an interpretation of the Contract Documents for implementation)

**Gypsum board finished to LEVEL 4, per shell and core documents, is acceptable for all painted surfaces.**

BY: Barry Koncel

SIGNED: \_\_\_\_\_

DATE: 3/21/2008

(RESPONSE DISTRIBUTION VIA ) FAX: \_\_\_\_\_ E-MAIL: x DATE: 3/21/2008

cc: Delmastro Eells: x

Architect: x

SUBS: \_\_\_\_\_