

**REQUEST FOR INFORMATION/CLARIFICATION**



7010 E Acorn Drive, Ste 104  
Scottsdale, Az 85254  
480.481.9699  
fax 480.425.8624

**RFI. # 025**

TO: Proteus Group  
223 West Erie - Suite 6W  
Chicago, Il 60610

DATE: March 21, 2008

PHONE: 312-337-7800  
FAX: 312-337-7805

REQUESTED BY: DELMASTRO + EELLS

PROJECT: Fortis College  
PROJ #: 10078

ATTN: Barry Koncel

SPEC REFERENCE : \_\_\_\_\_

REF: \_\_\_\_\_

DRAWING REFERENCE: \_\_\_\_\_

VERIFICATION

DISCREPANCY

OTHER

REQUEST :  Potential cost or schedule impact

→ Please confirm that R-11 is acceptable in lieu of the SAFB as shown on the drawings.

→

→

BY: J.Cotton

SIGNED: J Cotton

DATE: 21-Mar-08

**ARCHITECT'S/ENGINEER'S RESPONSE :**

(This information is provided as an interpretation of the Contract Documents for implementation)

**Per earlier email with Scott Fyffe, R-11 insulation is acceptable if it meets the same STC ratings as the equivalent amount of SAFB insulation indicated on the documents.**

BY: Barry Koncel

SIGNED: \_\_\_\_\_

DATE: 3/21/2008

(RESPONSE DISTRIBUTION VIA ) FAX: \_\_\_\_\_ E-MAIL: x DATE: 3/21/2008

cc: Delmastro Eells: x

Architect: x

SUBS: \_\_\_\_\_