

**REQUEST FOR INFORMATION/CLARIFICATION**



7010 E Acoma Drive, Ste 104  
Scottsdale, Az 85254  
480.481.9699  
fax 480.425.8624

**RFI. # 030**

TO: Proteus Group  
223 West Erie - Suite 6W  
Chicago, Il 60610

DATE: March 26, 2008

PHONE: 312-337-7800  
FAX: 312-337-7805

REQUESTED BY: DELMASTRO + EELLS

PROJECT: Fortis College  
PROJ #: 10078

ATTN: Barry Koncel

SPEC REFERENCE : \_\_\_\_\_

REF: \_\_\_\_\_

DRAWING REFERENCE: \_\_\_\_\_

VERIFICATION

DISCREPANCY

OTHER

REQUEST :  Potential cost or schedule impact

➔Per the Henry Schein representatives, what type of dental chair is going in X-Ray room #2109?



➔Galaxy m/n 4001 as shown at right and web link below. Provide power as shown on Henry Schein Sheets: SPE.2 Spec Number 5 / SPE.3 Detail D-5.RIK 3-26-08

➔[http://galaxymfg.com/index.php?cPath=8-51&product\\_id=212](http://galaxymfg.com/index.php?cPath=8-51&product_id=212)

BY: J.Cotton

SIGNED: J Cotton

DATE: 26-Mar-08

**ARCHITECT'S/ENGINEER'S RESPONSE :**

(This information is provided as an interpretation of the Contract Documents for implementation)

Empty response box for Architect/Engineer

BY: R. Kofron Henry Schein Dental

SIGNED: R. Kofron

DATE: 3/26/2008

(RESPONSE DISTRIBUTION VIA ) FAX: \_\_\_\_\_ MAIL: \_\_\_\_\_ DATE: \_\_\_\_\_

cc: Delmastro Eells: \_\_\_\_\_

Architect: \_\_\_\_\_

SUBS: \_\_\_\_\_