

REQUEST FOR INFORMATION/CLARIFICATION



7010 E Acorn Drive, Ste 104
Scottsdale, Az 85254
480.481.9699
fax 480.425.8624

RFI. # 038

TO: Proteus Group
223 West Erie - Suite 6W
Chicago, Il 60610

DATE: March 26, 2008

PHONE: 312-337-7800
FAX: 312-337-7805

REQUESTED BY: DELMASTRO + EELLS

PROJECT: Fortis College
PROJ #: 10078

ATTN: Barry Koncel

SPEC REFERENCE : _____

REF: _____

DRAWING REFERENCE: _____

VERIFICATION

DISCREPANCY

OTHE

REQUEST : Potential cost or schedule impact

⇒ Does the fume hood exhaust duct have to be continuously welded? If so, does it require any type of access door (1-hr rated)?

⇒

⇒

BY: J.Cotton

SIGNED: J. Cotton

DATE: 26-Mar-08

ARCHITECT'S/ENGINEER'S RESPONSE :

(This information is provided as an interpretation of the Contract Documents for implementation)

*See sheet M201 Mechanical Project Notes Letter "OO"
for fume hood ductwork specs.*

No access door is required.

BY: Wes Colgan

SIGNED: Wes Colgan

DATE: 3/26/08

(RESPONSE DISTRIBUTION VIA) FAX: _____ MAIL: _____ DATE: _____

cc: Delmastro Eells: _____

Architect: _____

SUBS: _____