REQUEST FOR INFORMATION/CLARIFICATION

Delmastro Eells
7010 E Acoma Drive, Ste 104
Scottsdale, Az 85254
480.481.9699
fax 480.425.8624

RFI. # 039

TO: Proteus Group
223 West Erie - Suite 6W
Chicago, Il 60610

PHONE: 312-337-7800
FAX: 312-337-7805

DATE: March 26, 2008

REQUESTED BY: DELMASTRO + EELLS

PROJECT: Fortis College
PROJ #: 10078

ATTN: Barry Koncel

REF:

SPEC REFERENCE :

DRAWING REFERENCE:

VERIFICATION [X] DISCREPANCY [ ] OTHER [ ]

REQUEST : [ ] Potential cost or schedule impact

➡Partition type 2 calls for "Sealant, both sides at UL listed fire stop assembly at rated partition." Please clarify if partition type 2 is a rated assembly, and if so, please provide the UL listing.

➡

➡

BY: J.Cotton SIGNED: J Cotton DATE: 26-Mar-08

ARCHITECT'S/ENGINEER'S RESPONSE :
(This information is provided as an interpretation of the Contract Documents for implementation)

Partition type 2 is not rated.

BY: Iwona Swift SIGNED: DATE: 3/27/2008

(RESPONSE DISTRIBUTION VIA) FAX: MAIL: DATE:

cc: Delmastro Eells: Architect:

SUBS: