

**REQUEST FOR INFORMATION/CLARIFICATION**



7010 E. Acorns Drive, Ste 104  
Scottsdale, Az 85254  
480.481.9699  
fax 480.425.8624

**RFI. # 042**

#08-10A

TO: Proteus Group  
223 West Erie - Suite 6W  
Chicago, IL 60610

DATE: March 28, 2008

PHONE: 312-337-7800  
FAX: 312-337-7805

REQUESTED BY: DELMASTRO + EELLS

PROJECT: Fortis College  
PROJ #: 10078

ATTN: Barry Koncel

SPEC REFERENCE: \_\_\_\_\_

REF: \_\_\_\_\_

DRAWING REFERENCE: \_\_\_\_\_

VERIFICATION

DISCREPANCY

OTHER

REQUEST :  Potential cost or schedule impact

- ⇒ Is a 1" fiberglass return air boot acceptable in lieu of the 30ga metal 1" lined box as specified? Please see attached.
- ⇒ Please note : Manufacturers spec sheet attached.
- ⇒

BY: J.Cotton

SIGNED: J Cotton

DATE: 28-Mar-08

**ARCHITECT'S/ENGINEER'S RESPONSE :**

(This information is provided as an interpretation of the Contract Documents for implementation)

*This is acceptable.*

BY: Wes Colgan

SIGNED: Wes Colgan

DATE: 3/31/08

(RESPONSE DISTRIBUTION VIA) FAX: \_\_\_\_\_ MAIL: \_\_\_\_\_ DATE: \_\_\_\_\_

cc: Delmastro Eells: \_\_\_\_\_

Architect: \_\_\_\_\_

SUBS: \_\_\_\_\_