

REQUEST FOR INFORMATION/CLARIFICATION

7018 E Adams Drive, Ste 104
 Scottsdale, AZ 85254
 480.481.9090
 Fax 480.425.0924

RFI. # 057

TO: Proteus Group
223 West Erie - Suite 6W
Chicago, IL 60610

DATE: April 14, 2008

PHONE: 312-337-7800
 FAX: 312-337-7805

REQUESTED BY: DELMASTRO + EELLS

PROJECT: Fortis College
 PROJ #: 10078

ATTN: Barry Koncel

SPEC REFERENCE: _____

REF: _____

DRAWING REFERENCE: _____

VERIFICATION

DISCREPANCY

OTHER

Keyed note 25 on P-102, calls for a 1/2" CW down in wall to backflow preventer and vending machine. Please specify location of stub out in student lounge (2129) and if it acceptable for backflow to be wall mounted.

BY: J. Colton

SIGNED: J. Colton

DATE: 14-Apr-08

ARCHITECT'S/ENGINEER'S RESPONSE:

(This information is provided as an interpretation of the Contract Documents for implementation)

SEE ARCHITECTURAL DRAWINGS FOR LOCATION OF STUB-OUT. BACKFLOW PREVENTOR IS A SMALL IN-LINE MODEL AND CAN BE MOUNTED VERTICALLY OR HORIZONTALLY.

BY: SCOTT GILDENMEISTER

SIGNED: [Signature]

DATE: 4-16-08

(RESPONSE DISTRIBUTION VIA) FAX: _____ MAIL: _____ DATE: _____

cc: Delmastro Eells

Architect: _____

SUBS: _____