

REQUEST FOR INFORMATION/CLARIFICATION



7010 E Acoma Drive, Ste 104
Scottsdale, Az 85254
480.481.9699
fax 480.425.8624

RFI. # 068

TO: Proteus Group
223 West Erie - Suite 6W
Chicago, Il 60610

DATE: April 15, 2008

PHONE: 312-337-7800
FAX: 312-337-7805

REQUESTED BY: DELMASTRO + EELLS

PROJECT: Fortis College
PROJ #: 10078

ATTN: Barry Koncel

SPEC REFERENCE :

REF:

DRAWING REFERENCE:

VERIFICATION

DISCREPANCY

OTHER

→The plans call for the water heater to be 480 volts, single phase, 12.5 amps.
Please confirm that this is acceptable.

BY: J. Cotton

SIGNED: J Cotton

DATE: 15-Apr-08

ARCHITECT'S/ENGINEER'S RESPONSE :

(This information is provided as an interpretation of the Contract Documents for implementation)

According to our documents that is correct. Verify with mechanical / plumbing that these values are true.

BY: Alan Duong

SIGNED:

DATE: 4/15/2008

(RESPONSE DISTRIBUTION VIA) FAX: MAIL: DATE:

cc: Delmastro Eells:

Architect:

SUBS: