

**REQUEST FOR INFORMATION/CLARIFICATION**



7010 E Acoma Drive, Ste 104  
Scottsdale, Az 85254  
480.481.9699  
fax 480.425.8624

**RFI. # 070**

TO: Proteus Group  
223 West Erie - Suite 6W  
Chicago, Il 60610

DATE: April 15, 2008

PHONE: 312-337-7800  
FAX: 312-337-7805

REQUESTED BY: DELMASTRO + EELLS

PROJECT: Fortis College  
PROJ #: 10078

ATTN: Barry Koncel

SPEC REFERENCE :

REF:

DRAWING REFERENCE:

VERIFICATION

DISCREPANCY

OTHER

➡Please reference E203, note 3 refers to a Remote Panel supplied by H.S. and calls for low voltage. H.S. sheet SPE.2, note 32A indicates to mount this box at 60" a.f.f. and mentions air, water and vac, which is not shown on H.S. sheet SPE.1. Please verify what we are to do at this location, and what is required inside the wall. **Correct, It will not be shown on sheet SPE.1 as it pertains to ELECTRICAL only. We need to have Low Voltage wires ( 4 SETS of 18-3) run from #32A to Each piece of equipment in the Mechanical closet. i.e. Compressor, Vacuum and Water Solenoid. rlk.4.16.08**

BY: J. Cotton

SIGNED: J Cotton

DATE: 15-Apr-08

**ARCHITECT'S/ENGINEER'S RESPONSE :**

(This information is provided as an interpretation of the Contract Documents for implementation)

[Empty response box]

BY: \_\_\_\_\_ SIGNED: \_\_\_\_\_ DATE: \_\_\_\_\_

(RESPONSE DISTRIBUTION VIA ) FAX: \_\_\_\_\_ MAIL: \_\_\_\_\_ DATE: \_\_\_\_\_

cc: Delmastro Eells: \_\_\_\_\_ Architect: \_\_\_\_\_

SUBS: \_\_\_\_\_